

BUILDING ID

195

Metroplex Fire Department








6855 S Havana Street, Centennial, CO 80112, (303) 721-8100

FOLLOW-UP FIRE INSPECTION

JOB NUMBER

31905

STREET ADDRESS 7164 E Dry Creek Road		SUITE NUMBER B	MAP NUMBER F-21	ZIP CODE 80113
BUSINESS NAME Dry Creek Office Village Bldg B		CONTACT FOR INSPECTION APPOINTMENT Lucio Zimlich		BUSINESS PHONE (555) 424-5939

ITEM	DATE FOUND	DESCRIPTION OF VIOLATION & ADDITIONAL INFORMATION
1 <small>Corrected?</small> <input type="checkbox"/>	04/19/2007 	Obstructed fire hydrant [150] ☐ North side of building near entrance. Bushes must be cut back.
2 <small>Corrected?</small> <input type="checkbox"/>	04/19/2007 	Keys missing or do not work [251] ☐ Two sets of master keys are required in the key box
3 <small>Corrected?</small> <input type="checkbox"/>	04/19/2007 	Lack of required exit door identification sign [311] ☐ Suite number must be visible from the street in 4" high contrast letters
4 <small>Corrected?</small> <input type="checkbox"/>	04/19/2007 	Designated exit door locked or blocked [310] ☐ Both leaves of the front door must remain unlocked during business hours
5 <small>Corrected?</small> <input type="checkbox"/>	04/19/2007 	Exit corridor obstructed [323] ☐ Storage not allowed in the main corridor by the break room
6 <small>Corrected?</small> <input type="checkbox"/>	04/19/2007 	Open, loose, or broken electrical box or fixture [411] ☐ Replace cover plate on outlet behind reception desk
7 <small>Corrected?</small> <input type="checkbox"/>	04/19/2007 	Test records not available for fire alarm [656] ☐ Alarm system must be tested every 6 months. Contact our office to register for confidence testing notifications.

An inspection has been made at this location to determine if any fire code violations exist. This document shall serve as your official fire code violation notice. A list of violations is attached. If you do not understand any of the listed fire code violations, the inspector(s) shall explain each violation. Regardless, all fire code violations must be corrected immediately. A re-inspection of the premises will be made at a future date to verify that the required corrections have been made. Failure to promptly correct fire code violations shall cause the owner or responsible party, to be assessed a re-inspection fee, and such penalties as the District may deem appropriate, as permitted under C.R.S. Section 32-1-1001(j). The owner or responsible party may also be charged for violating the provisions of C.R.S. 32-1-1002, or such municipal ordinances or state statutes as may exist, which may subject the owner or responsible part to injunctive actions up to and including the closing of the property. Violators of the Fire District's fire code are also subject to criminal charges under State law, and may be charged with and guilty of a misdemeanor for each day on which such a violation occurs.

SIGNATURE OF BUSINESS MANAGER, OWNER, OR RESPONSIBLE PARTY			TITLE			DATE SIGNED		
INSPECTOR'S NAME (PLEASE PRINT)		LOGIN / EMAIL		DATE COMPLETED		TIME IN	TIME OUT	NO. OF INSPECTORS
FOLLOW-UP #	DATE ISSUED	ASSIGNMENT			PAGE	OF		<input type="checkbox"/> Immediate Bureau Action Requested
1	06/12/2007	Barrino, Fantasia			1	1		

Primary inspection completed on 04/19/2007 by Aaron Carter.

